

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE 1 OF 34 PAGES	
2. AMENDMENT/MODIFICATION NO. 01		3. EFFECTIVE DATE 03/20/2008		4. REQUISITION/PURCHASE REQ. NO. CB 080037		5A. TITLE: Custom Crowd Control Barriers	
						5B. PROJECT NO.	
6. ISSUED BY AOC - Procurement Division 2nd & D Streets, SW Room H2-263 WASHINGTON, DC 20515		CODE 9901		7. ADMINISTERED BY (If other than Item 6) AOC - Procurement Division 2nd & D Streets, SW ATTN: Shola Matthews-Aroloye Room H2-263 WASHINGTON, DC 20515		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, country, state and ZIP Code)						(X)	
						9A. AMENDMENT OF SOLICITATION NO. RFP080011	
						X 9B. DATED (SEE ITEM 11) 03/01/2008	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 11)	
CODE				FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 7 and 14, and returning 2 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)
SEE LINE ITEMS

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)
AMENDMENT 001 TO RFP080011 IS BEING ISSUED TO RESPOND TO CONTRACTORS' QUESTIONS. PROPOSALS ARE DUE ON MARCH 31, 2008 @ 1:00P.M. LOCAL TIME.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Shola Matthews	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)	16C. DATE SIGNED

NSN 7540-01-152-8070
Previous edition unusable

STANDARD FORM 30 (REV. 10-83)
Prescribed by GSA FAR (48 CFR) 53.243

RFP080011

CONTRACTORS' QUESTIONS & GOVERNMENT'S RESPONSE
RFP080011 Amendment 01

Contractor's Question 1:

Are all of the pickets to be tubular aluminum, or only the 1 x 1 pickets?

Government's Response:

The 1" Pickets should be tubular, so that the rail sections will not become excessively heavy. The smaller profile Pickets can be either tubular or solid at the fabricator's option.

Contractor's Question 2:

What is the dimension of the support member under the custom extruded handrail? Is this member solid or tubular?

Government's Response:

The rectangular section under the handrail profile is 3/4" x 2" and it is solid due to the stresses at each end where its attachment pin is fastened.

Contractor's Question 3:

You have given us the width of the extruded handrail as 2 3/4". What is the height dimension?

Government's Response:

**Handrail on AOC's existing sample rail section is 2-3/4" wide x 1" high. To see Mockup Rail Sections in Person: Interested Parties can contact AOC's Mr. Perry Caswell, at the following phone Numbers:
202-228-0151 Work Phone
202-329-7084 Work Cell Phone**

Contractor's Question 4:

On the bid form, will the total cost be the unit cost times 150 on Items 1, 2 and 3, assuming no discounts are offered?

Government's Response:

Yes. See attached section titled "Section B - Supplies or Services and Prices/Costs" for the Pricing Schedule.

Section B - Supplies or Services and Prices/Costs

The Contractor shall fabricate and supply Custom Crowd Control Barriers for use in the U.S. Capitol Building Washington, D.C. in accordance with the terms and conditions of the contract that results from this solicitation.

BASE

Number	Commodity Name	Quantity	Unit of Issue	Unit Price (\$)	Total Cost (\$, Inc. disc)
1	Custom Crowd Control Barriers	Total : 1.00	EA	\$	\$
<p>Description:Base- for the fabrication and delivery of a maximum of one hundred and fifty (150) custom crowd control barriers. Fabrication of custom crowd control barriers done in welded aluminum and painted to look like weathered bronze. The handrail profile is a custom extrusion and the posts are custom castings made to simulate original bronze railing and posts at the United States Capitol Building. Each section is made up of two posts and a section of railing that simply hangs from pins that interlock with tabs that protrude from the typical posts.</p> <p>A couple of modifications will be required to the mockup that is shown in the photos. We'll need some of the posts to have tabs such that we can make 90 degree angles, as well as the slight angles that the mockup allows. Also, the sections need to assemble easily and without tools, but there is a need to add something like clevis pins to make them slightly more difficult to disassemble than just lifting off the rail section. The attached photos should adequately describe what we are seeking to have fabricated, however, the mockup rail sections are available to see in person should that be deemed worthwhile. Our intent is to purchase approximately 150 railing sections immediately, with the option of additional purchases over the next two years.</p>					
2	Custom Crowd Control Barriers	Total : 1.00	EA	\$	\$
<p>Description:Option 1- for the fabrication and delivery of a maximum of one hundred and fifty (150) custom crowd control barriers.</p>					
3	Custom Crowd Control Barriers	Total : 1.00	EA	\$	\$
<p>Description:Option 2- for the fabrication and delivery of a maximum of one hundred and fifty (150) custom crowd control barriers.</p>					

Lump-Sum Price for Base

\$

B2.1

B2. UNIT PRICE

.1 The unit price shall include all costs associated with fabrication and delivery of Custom Crowd Control Barriers procured under the contract that results from RFP080011. Unit price shall take precedence over total price.